



January 31, 2024

Michael Ferraro  
OHM BOCES Utica City School District  
320 Elizabeth St.  
Utica, NY 13501

RE: Project: ALBANY ELEMENTARY 1/11  
Pace Project No.: 70284328

Dear Michael Ferraro:

Enclosed are the analytical results for sample(s) received by the laboratory on January 16, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jack M. Germano  
jack.germano@pacelabs.com  
516-370-6012  
Project Manager

Enclosures

cc: Erica Molina, OHM BOCES Utica City School District  
OHM BOCES Safety Services, OHM BOCES Utica City  
School District  
Tiffany Service, OHM BOCES Utica City School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 1</b>		<b>Lab ID: 70284328001</b>	Collected: 01/11/24 05:21	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:28	7439-92-1	

<b>Sample: ALBANY 3</b>		<b>Lab ID: 70284328010</b>	Collected: 01/11/24 05:22	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:30	7439-92-1	

<b>Sample: ALBANY 4</b>		<b>Lab ID: 70284328011</b>	Collected: 01/11/24 05:23	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:31	7439-92-1	

<b>Sample: ALBANY 6</b>		<b>Lab ID: 70284328012</b>	Collected: 01/11/24 05:24	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:33	7439-92-1	

<b>Sample: ALBANY 7</b>		<b>Lab ID: 70284328013</b>	Collected: 01/11/24 05:25	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 9</b>		<b>Lab ID: 70284328014</b>	Collected: 01/11/24 05:26	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:36	7439-92-1	

<b>Sample: ALBANY 10</b>		<b>Lab ID: 70284328015</b>	Collected: 01/11/24 05:27	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:38	7439-92-1	

<b>Sample: ALBANY 12</b>		<b>Lab ID: 70284328016</b>	Collected: 01/11/24 05:28	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.3	ug/L	1.0	1		01/18/24 12:39	7439-92-1	

<b>Sample: ALBANY 13</b>		<b>Lab ID: 70284328017</b>	Collected: 01/11/24 05:29	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:44	7439-92-1	

<b>Sample: ALBANY 14 TEACHERS LOUNGE</b>		<b>Lab ID: 70284328018</b>	Collected: 01/11/24 05:30	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 12:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 16</b>	<b>Lab ID: 70284328019</b>	Collected: 01/11/24 05:49	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		01/18/24 12:47	7439-92-1	

<b>Sample: ALBANY 17</b>	<b>Lab ID: 70284328020</b>	Collected: 01/11/24 05:50	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.1</b>	ug/L	1.0	1		01/18/24 12:48	7439-92-1	

<b>Sample: ALBANY 18</b>	<b>Lab ID: 70284328021</b>	Collected: 01/11/24 05:53	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.8</b>	ug/L	1.0	1		01/18/24 12:50	7439-92-1	

<b>Sample: ALBANY 19</b>	<b>Lab ID: 70284328022</b>	Collected: 01/11/24 05:54	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.9</b>	ug/L	1.0	1		01/18/24 12:54	7439-92-1	

<b>Sample: ALBANY 20</b>	<b>Lab ID: 70284328023</b>	Collected: 01/11/24 05:51	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>1.6</b>	ug/L	1.0	1		01/18/24 13:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 21</b>	<b>Lab ID: 70284328024</b>	Collected: 01/11/24 05:48	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		01/18/24 13:06	7439-92-1	

<b>Sample: ALBANY 22</b>	<b>Lab ID: 70284328025</b>	Collected: 01/11/24 05:45	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 13:08	7439-92-1	

<b>Sample: ALBANY 23 RM 203</b>	<b>Lab ID: 70284328026</b>	Collected: 01/11/24 05:47	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		01/18/24 13:10	7439-92-1	

<b>Sample: ALBANY 24</b>	<b>Lab ID: 70284328027</b>	Collected: 01/11/24 06:32	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 13:11	7439-92-1	

<b>Sample: ALBANY 29 DF</b>	<b>Lab ID: 70284328028</b>	Collected: 01/11/24 06:06	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 13:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 30</b>	<b>Lab ID: 70284328029</b>	Collected: 01/11/24 05:56	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>3.4</b>	ug/L	1.0	1		01/18/24 13:14	7439-92-1	

<b>Sample: ALBANY 31</b>	<b>Lab ID: 70284328030</b>	Collected: 01/11/24 06:00	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>19.3</b>	ug/L	1.0	1		01/18/24 13:16	7439-92-1	

<b>Sample: ALBANY 32</b>	<b>Lab ID: 70284328031</b>	Collected: 01/11/24 06:01	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		01/18/24 13:20	7439-92-1	

<b>Sample: ALBANY 33</b>	<b>Lab ID: 70284328032</b>	Collected: 01/11/24 06:05	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>11.8</b>	ug/L	1.0	1		01/18/24 13:23	7439-92-1	

<b>Sample: ALBANY 40</b>	<b>Lab ID: 70284328033</b>	Collected: 01/11/24 06:02	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>5.5</b>	ug/L	1.0	1		01/18/24 13:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 41</b>		<b>Lab ID: 70284328034</b>	Collected: 01/11/24 06:03	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>14.0</b>	ug/L	1.0	1		01/18/24 13:28	7439-92-1	

<b>Sample: ALBANY 42</b>		<b>Lab ID: 70284328035</b>	Collected: 01/11/24 05:57	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>8.6</b>	ug/L	1.0	1		01/18/24 13:33	7439-92-1	

<b>Sample: ALBANY 47 DF ACROSS FROM 110</b>		<b>Lab ID: 70284328036</b>	Collected: 01/11/24 05:36	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		01/18/24 13:43	7439-92-1	

<b>Sample: ALBANY 52</b>		<b>Lab ID: 70284328037</b>	Collected: 01/11/24 05:38	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>1.5</b>	ug/L	1.0	1		01/18/24 13:57	7439-92-1	

<b>Sample: ALBANY 53</b>		<b>Lab ID: 70284328038</b>	Collected: 01/11/24 05:39	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>1.0</b>	ug/L	1.0	1		01/18/24 14:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 54</b>		<b>Lab ID: 70284328039</b>	Collected: 01/11/24 05:40	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.7</b>	ug/L	1.0	1		01/18/24 14:02	7439-92-1	

<b>Sample: ALBANY 55</b>		<b>Lab ID: 70284328040</b>	Collected: 01/11/24 05:41	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.0</b>	ug/L	1.0	1		01/18/24 14:03	7439-92-1	

<b>Sample: ALBANY 60</b>		<b>Lab ID: 70284328041</b>	Collected: 01/11/24 06:18	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		01/18/24 14:05	7439-92-1	

<b>Sample: ALBANY 61</b>		<b>Lab ID: 70284328042</b>	Collected: 01/11/24 06:20	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		01/18/24 14:06	7439-92-1	

<b>Sample: ALBANY 62</b>		<b>Lab ID: 70284328043</b>	Collected: 01/11/24 06:21	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>8.7</b>	ug/L	1.0	1		01/18/24 14:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 63</b>	<b>Lab ID: 70284328044</b>	Collected: 01/11/24 06:27	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.2	ug/L	1.0	1		01/18/24 14:10	7439-92-1	

<b>Sample: ALBANY 64</b>	<b>Lab ID: 70284328045</b>	Collected: 01/11/24 06:28	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 14:11	7439-92-1	

<b>Sample: ALBANY 70</b>	<b>Lab ID: 70284328046</b>	Collected: 01/11/24 06:24	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.1	ug/L	1.0	1		01/18/24 14:16	7439-92-1	

<b>Sample: ALBANY 71</b>	<b>Lab ID: 70284328047</b>	Collected: 01/11/24 06:25	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.6	ug/L	1.0	1		01/18/24 14:17	7439-92-1	

<b>Sample: ALBANY 72</b>	<b>Lab ID: 70284328048</b>	Collected: 01/11/24 06:19	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	19.2	ug/L	1.0	1		01/18/24 14:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

<b>Sample: ALBANY 73</b>		<b>Lab ID: 70284328049</b>	Collected: 01/11/24 06:12	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		01/18/24 14:20	7439-92-1	

<b>Sample: ALBANY 74 A</b>		<b>Lab ID: 70284328050</b>	Collected: 01/11/24 06:13	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 14:22	7439-92-1	

<b>Sample: ALBANY 74 B</b>		<b>Lab ID: 70284328051</b>	Collected: 01/11/24 06:14	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 14:24	7439-92-1	

<b>Sample: ALBANY 77</b>		<b>Lab ID: 70284328052</b>	Collected: 01/11/24 06:15	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 14:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

QC Batch:	334391	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70284328001, 70284328010, 70284328011, 70284328012, 70284328013, 70284328014, 70284328015, 70284328016, 70284328017, 70284328018, 70284328019, 70284328020, 70284328021		

METHOD BLANK:	1718339	Matrix:	Water
Associated Lab Samples:	70284328001, 70284328010, 70284328011, 70284328012, 70284328013, 70284328014, 70284328015, 70284328016, 70284328017, 70284328018, 70284328019, 70284328020, 70284328021		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 12:03	

LABORATORY CONTROL SAMPLE: 1718340						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE: 1718342							
Parameter	Units	70284327012 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	51.0	101	70-130	

MATRIX SPIKE SAMPLE: 1718344							
Parameter	Units	70284327013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	51.5	103	70-130	

SAMPLE DUPLICATE: 1718341					
Parameter	Units	70284327012 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1718343					
Parameter	Units	70284327013 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

QC Batch:	334392	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70284328022, 70284328023, 70284328024, 70284328025, 70284328026, 70284328027, 70284328028, 70284328029, 70284328030, 70284328031, 70284328032, 70284328033, 70284328034, 70284328035		

METHOD BLANK:	1718345	Matrix:	Water
Associated Lab Samples:	70284328022, 70284328023, 70284328024, 70284328025, 70284328026, 70284328027, 70284328028, 70284328029, 70284328030, 70284328031, 70284328032, 70284328033, 70284328034, 70284328035		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 12:51	

LABORATORY CONTROL SAMPLE: 1718346						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.8	104	85-115	

MATRIX SPIKE SAMPLE: 1718348							
Parameter	Units	70284328022 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.9	50	52.2	99	70-130	

MATRIX SPIKE SAMPLE: 1718350							
Parameter	Units	70284328023 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.6	50	52.5	102	70-130	

SAMPLE DUPLICATE: 1718347					
Parameter	Units	70284328022 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.9	2.8	3	

SAMPLE DUPLICATE: 1718349					
Parameter	Units	70284328023 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.6	1.6	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

QC Batch:	334393	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70284328036, 70284328037, 70284328038, 70284328039, 70284328040, 70284328041, 70284328042, 70284328043, 70284328044, 70284328045, 70284328046, 70284328047, 70284328048, 70284328049, 70284328050, 70284328051, 70284328052		

METHOD BLANK:	1718351	Matrix:	Water
Associated Lab Samples:	70284328036, 70284328037, 70284328038, 70284328039, 70284328040, 70284328041, 70284328042, 70284328043, 70284328044, 70284328045, 70284328046, 70284328047, 70284328048, 70284328049, 70284328050, 70284328051, 70284328052		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 13:40	

LABORATORY CONTROL SAMPLE:	1718352					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.3	105	85-115	

MATRIX SPIKE SAMPLE:	1718354						
Parameter	Units	70284328036 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.5	105	70-130	

MATRIX SPIKE SAMPLE:	1718356						
Parameter	Units	70284330007 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	10.2	50	59.5	99	70-130	

SAMPLE DUPLICATE:	1718353					
Parameter	Units	70284328036 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1718355					
Parameter	Units	70284330007 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	10.2	10.4	2		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: ALBANY ELEMENTARY 1/11

Pace Project No.: 70284328

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70284328001	ALBANY 1	EPA 200.8	334391		
70284328010	ALBANY 3	EPA 200.8	334391		
70284328011	ALBANY 4	EPA 200.8	334391		
70284328012	ALBANY 6	EPA 200.8	334391		
70284328013	ALBANY 7	EPA 200.8	334391		
70284328014	ALBANY 9	EPA 200.8	334391		
70284328015	ALBANY 10	EPA 200.8	334391		
70284328016	ALBANY 12	EPA 200.8	334391		
70284328017	ALBANY 13	EPA 200.8	334391		
70284328018	ALBANY 14 TEACHERS LOUNGE	EPA 200.8	334391		
70284328019	ALBANY 16	EPA 200.8	334391		
70284328020	ALBANY 17	EPA 200.8	334391		
70284328021	ALBANY 18	EPA 200.8	334391		
70284328022	ALBANY 19	EPA 200.8	334392		
70284328023	ALBANY 20	EPA 200.8	334392		
70284328024	ALBANY 21	EPA 200.8	334392		
70284328025	ALBANY 22	EPA 200.8	334392		
70284328026	ALBANY 23 RM 203	EPA 200.8	334392		
70284328027	ALBANY 24	EPA 200.8	334392		
70284328028	ALBANY 29 DF	EPA 200.8	334392		
70284328029	ALBANY 30	EPA 200.8	334392		
70284328030	ALBANY 31	EPA 200.8	334392		
70284328031	ALBANY 32	EPA 200.8	334392		
70284328032	ALBANY 33	EPA 200.8	334392		
70284328033	ALBANY 40	EPA 200.8	334392		
70284328034	ALBANY 41	EPA 200.8	334392		
70284328035	ALBANY 42	EPA 200.8	334392		
70284328036	ALBANY 47 DF ACROSS FROM 110	EPA 200.8	334393		
70284328037	ALBANY 52	EPA 200.8	334393		
70284328038	ALBANY 53	EPA 200.8	334393		
70284328039	ALBANY 54	EPA 200.8	334393		
70284328040	ALBANY 55	EPA 200.8	334393		
70284328041	ALBANY 60	EPA 200.8	334393		
70284328042	ALBANY 61	EPA 200.8	334393		
70284328043	ALBANY 62	EPA 200.8	334393		
70284328044	ALBANY 63	EPA 200.8	334393		
70284328045	ALBANY 64	EPA 200.8	334393		
70284328046	ALBANY 70	EPA 200.8	334393		
70284328047	ALBANY 71	EPA 200.8	334393		
70284328048	ALBANY 72	EPA 200.8	334393		
70284328049	ALBANY 73	EPA 200.8	334393		
70284328050	ALBANY 74 A	EPA 200.8	334393		
70284328051	ALBANY 74 B	EPA 200.8	334393		
70284328052	ALBANY 77	EPA 200.8	334393		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





Pace® Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

Company Name:  
Street Address:  
925 York St Utica, NY 13502

Customer Project #:  
Project Name:  
Albany Elementary

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET [ ] New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead In School DW

[ ] Level II [ ] Level III [ ] Level IV

[ ] EQUIS [ ] Other: \_\_\_\_\_

[ ] Other: \_\_\_\_\_

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (O), Wipe (WP), Tissue (TS), Blossay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Metric *	Comp / Grab	Collected		Composite End	Res. CL2	Number & Type of Containers
			Date	Time			
Albany 1	DW	G	1-11-2024	0521		1	Plastic
3				0522			
4				0527			
6				0524			
7				0525			
9				0526			
10				0527			
12				0528			
13				0529			
14 Teachers Lounge				0530			

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Collected By: Chris Putzer  
Signature: *Chris Putzer*

Received by/Company: (Signature) *Chris Putzer*

Date/Time: 1-15-24 16:00

Received by/Company: (Signature) *Chris Putzer*

Date/Time: 1-16-24 08:00

Received by/Company: (Signature) *Chris Putzer*

Date/Time: 1-16-24 08:00

Received by/Company: (Signature) *Chris Putzer*

Date/Time: 1-16-24 08:00

Received by/Company: (Signature) *Chris Putzer*

Date/Time: 1-16-24 08:00

Received by/Company: (Signature) *Chris Putzer*

Date/Time: 1-16-24 08:00

Received by/Company: (Signature) *Chris Putzer*

Date/Time: 1-16-24 08:00

Received by/Company: (Signature) *Chris Putzer*

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Contact/Report To: Tiffany Service

Phone #: 315-927-4110

E-Mail: [taseservice@uticaschools.org](mailto:taseservice@uticaschools.org)

Cc E-Mail:

Invoice To: Tiffany Service

Invoice E-Mail: [taseservice@uticaschools.org](mailto:taseservice@uticaschools.org)

Purchase Order # (if applicable):

Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead In School DW

Rush (Pre-approval required):

[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other:

Date Results Requested: Standard 10 business day

Field Filtered (if applicable): [ ] Yes [ ] No

Analysts:

Preservation non-conformance identified for

Lab Use Only

Proj. Mgr: Lori Beyer

AccNum / Client ID:

Table #:

Profile / Template: X

Prelog / Bottle Ord. ID:

Sample Comment

Additional Instructions from Pace:

# Coolers: Thermometer ID: Connection Factor (°C) Obs. Temp (°C) Corrected Temp (°C)

2-cool TH711 -0.4 8.7 9.1

Date/Time: 1-15-24 17:35

Tracking Number:

Date/Time: 1/16/24 4:10

Delivered by: [ ] In-Person [ ] Courier

[ ] FedEx [ ] UPS [ ] Other

Date/Time: 1/16/24 8:00

Page: 1 of 5

ENV-FRM-CORQ-0019\_V01\_082123 ©

LAB USE ONLY - Affix Workorder/Login Label Here



WO#: 70284328



70284328

Specy Contain...

Identify Container Preservative Type\*\*

\*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MAOH, (11) Other

Analysis Requested

Preservation non-conformance identified for

Lab Use Only

Proj. Mgr: Lori Beyer

AccNum / Client ID:

Table #:

Profile / Template: X

Prelog / Bottle Ord. ID:

Sample Comment

Additional Instructions from Pace:

# Coolers: Thermometer ID: Connection Factor (°C) Obs. Temp (°C) Corrected Temp (°C)

2-cool TH711 -0.4 8.7 9.1

Date/Time: 1-15-24 17:35

Tracking Number:

Date/Time: 1/16/24 4:10

Delivered by: [ ] In-Person [ ] Courier

[ ] FedEx [ ] UPS [ ] Other

Date/Time: 1/16/24 8:00

Page: 1 of 5

ENV-FRM-CORQ-0019\_V01\_082123 ©



# CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

**Pace®** Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

Company Name:  
Street Address:  
Albany Elementary  
525 York St Utica, NY 13502

Customer Project #:  
Project Name:  
Albany Elementary

Site Collection Info/Facility ID (as applicable):  
Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET [ ] NY

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead In School DW  
Rush (Pre-approval required):  
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other

Date Results Requested:  
Standard 10 business day  
Field Filtered (if applicable): [ ] Yes [ ] No

Matrix Codes (Matrix in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (CL), Wipe (WP), Tissue (TS), Biossary (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID  
Albany 30  
31  
32  
33  
40  
41  
42  
43 DF 4 cans from 110  
52  
53

Matrix \*  
DW G  
Comp / Grab  
Date  
Time  
Collected (or Composite Start)  
Time  
Composite End  
Date  
Time  
Res. CL2  
Plastic  
Glass  
Number & Type of Containers

LAB USE ONLY - Affix Worker/Login Label Here



Scan QR Code for Instructions

Specify Container Size \*\*  
Identify Container Preservative Type\*\*  
Analysis Requested

Preservation non-conformance identified for  
Proj. Mgr:  
AcctNum / Client ID:  
Table #:  
Profile / Template:  
Pratig / Bottle Ord. ID:  
Sample Comment

Lab Use Only  
Preservation non-conformance identified for

Additional Instructions from Pace®:  
Thermometer ID:  
Correction Factor (°C):  
Obs. Temp. (°C):  
Connected Temp. (°C):  
# Coolant:  
Date/Time:  
Tracking Number:

Delivered by: [ ] In-Person [ ] Courier  
[ ] FedEx [ ] UPS [ ] Other

Page: 3 of 5  
ENV-FRM-CORQ-0019\_V01\_082123 ©

Terms and Conditions found at: https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Containers: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other

Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Additional Instructions from Pace®:  
Thermometer ID:  
Correction Factor (°C):  
Obs. Temp. (°C):  
Connected Temp. (°C):  
# Coolant:  
Date/Time:  
Tracking Number:

Delivered by: [ ] In-Person [ ] Courier  
[ ] FedEx [ ] UPS [ ] Other

Page: 3 of 5  
ENV-FRM-CORQ-0019\_V01\_082123 ©

Terms and Conditions found at: https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Signature: Chris Putzer  
Received by/Company: (Signature)

Signature: [Signature]  
Received by/Company: (Signature)

Signature: [Signature]  
Received by/Company: (Signature)

Signature: [Signature]  
Received by/Company: (Signature)

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Customer Remarks / Special Conditions / Possible Hazards:  
Lead



Pace\* Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

Company Name:  
Street Address:  
Ulrica Central School District  
929 York St Ulrica, NY 13502

Customer Project #:  
Project Name:  
Albany Elementary

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [ ] AK [ ] MT [ ] CT [ ] ET [ ] AT  
Data Deliverables:  
[ ] Level II [ ] Level III [ ] Level IV  
[ ] LEQUIS  
[ ] Other

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW  
Rush (Pre-approval required)  
[ ] 12 Day [ ] 3 day [ ] 5 day [ ] Other  
Date Results Requested: Standard 10 business day  
Field Filtered (if applicable): [ ] Yes [ ] No  
Analysis:

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End	Res. CL2	Number & Type of Containers
			Date	Time			
Albany 54	DW	G	1-11-2024	0540			1
55				0541			
60				0618			
61				0620			
62				0621			
63				0627			
64				0628			
70				0624			
71				0625			
72				0619			

Customer Remarks / Special Conditions / Possible Hazards:  
Lead

Requisitioned by/Company (Signature):  
Date/Time:  
1-15-24 16:00

Requisitioned by/Company (Signature):  
Date/Time:  
1-16 8:00

Requisitioned by/Company (Signature):  
Date/Time:  
1-16 8:00

Requisitioned by/Company (Signature):  
Date/Time:  
1-16 8:00

Subbing a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace\* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Contact/Report To:  
Phone #: 315-927-4110  
E-Mail: taservice@uticaschools.org  
Cc E-Mail:

Invoice To:  
Invoice E-Mail: taservice@uticaschools.org

Purchase Order # (if applicable):  
Quote #:

County / State origin of sample(s):  
New York

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [ ] Yes [ ] No  
Analysis:

200's Drinking Water (Pb only)

Sample Comment	Res. CL2	Number & Type of Containers
		1

Additional instructions from Pace\*:

# Coolers: 2-04  
Thermometer ID: T424  
Correction Factor (°C): +0.4  
Obs. Temp. (°C): 8.7  
Corrected Temp. (°C): 9.1  
Date/Time: 1-15-24 17:25  
Tracking Number:

Delivered by: [ ] In-Person [ ] Counter  
Date/Time: 1/16/24 8:00  
Date/Time: 1/16/24 8:00

Page: 4 of 5

ENV-FRM-CORQ-0019\_V01\_082123



Scan QR Code for Instructions

Specify Container Size \*\*  
\*\*\* Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 50mL, (7) 25mL, (8) 10mL, (9) 5mL, (10) 1mL, (11) Other

Identify Container Preservative Type\*\*\*  
\*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Analysis Requested

Lab Use Only  
Proj. Migr:  
Lori Bayer  
AccNum / Client ID:  
Table #:  
Profile / Template:  
K  
Prelog / Bottle Ord. ID:  
Preservation non-compliance identified for sample.

LAB USE ONLY - AMIX WorkOrder/LogIn Label Here





Pace® Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

Company Name:  
Ulrika Central School District  
Street Address:  
929 York St Utica, NY 13502

Customer Project #:  
Project Name:  
Albany K12/UTAS

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET [ ] AT

Data Deliverables:

[ ] Level II [ ] Level III [ ] Level IV  
[ ] EQUIS  
[ ] Other:

Regulatory Program (DW, RCRA, etc.) as applicable: NY Land In School DW

Rush (Pre-approval required):  
[ ] 2 Day [ ] 3 day [ ] 5 day [ ] Other:

Date Results Requested:  
Standard 30 business day

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:  
DW PWSID # or WW Permit # as applicable:

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID

Matrix \* Comp / Grab

Date (or Composite Start) Time

Composite End Date Time

Rel. CL3

Number & Type of Containers Plastic Glass

Albany 23 DW G 1/14/2024 0612 1

74g ↓ 0613 ↓

746 ↓ 0614 ↓

77 ↓ 0615 ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Contact/Report To: Tiffany Service

Phone #: 315-927-4110

E-Mail: [taservice@uticaschools.org](mailto:taservice@uticaschools.org)

Cc E-Mail:

Invoice To: Tiffany Service

Invoice E-Mail: [taservice@uticaschools.org](mailto:taservice@uticaschools.org)

Purchase Order # (if applicable):

Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Land In School DW

Rush (Pre-approval required):

Date Results Requested:

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:

DW PWSID # or WW Permit # as applicable:

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID

Matrix \* Comp / Grab

Date (or Composite Start) Time

Composite End Date Time

Rel. CL3

Number & Type of Containers Plastic Glass

Albany 23 DW G 1/14/2024 0612 1

74g ↓ 0613 ↓

746 ↓ 0614 ↓

77 ↓ 0615 ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓

↓ ↓ ↓ ↓ ↓



Scan QR Code for Instructions

Specify Container Size \*\*

Identify Container Preservative Type\*\*\*

Analysis Requested

Proj. Mgr:

Loft Beyer

AcctNum / Client ID:

Table #:

Profile / Template:

X

Presig / Bottle Ord. ID:

Sample Comment

Preservation non-conformance identified for

sample

Lab Use Only

Additional Instructions from Pace:

# Coolant: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

2-by TH211 40.4 9.7 9.1

Date/Time: 1/16/24 14:35 Tracking Number:

Date/Time: 1/16/24 9:00 Delivered by: [ ] In-Person [ ] Courier

Date/Time: 1/16/24 8:00 [ ] FedEx [ ] UPS [ ] Other

Date/Time: Page: of

ENV-FRM-CORQ-0019\_V01\_082123

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>